



IEEE ENERGY CONVERSION CONGRESS & EXPO PHOENIX, ARIZONA, USA ☀️ OCT. 20-24

VEHICLE-TO-GRID ANALYSIS TO REDUCE ELECTRICAL PEAK LOAD IN THE SAN DIEGO AREA IN 2030

Rafael Aranzabal¹, Jose Torre-Bueno², Sridhar Seshagiri³

¹ University of the Basque Country, Spain

² Center for Community Energy, San Diego, USA

³ San Diego State University, San Diego, USA




TABLE OF CONTENT

- 01 Introduction
- 02 Contributions & Brief Literature
- 03 Methodology
- 04 Cases of Study & Results
- 05 Gantt Diagram
- 06 Cost Benefit Analysis
- 07 Conclusions


1. INTRODUCTION

COMPANY APPROACH




1. INTRODUCTION

SCOPE



POLICY BACKGROUND





- California leading innovator in energy policy
- Transportation responsible for 38% GHG emissions
- Implementing clean transportation policies crucial

- Executive order B-48-18 Jan 2018
1.5 million ZEVs on California's roadways by 2025 and 5 million by 2030
- Senate Bill 100 (DeLeon) 2018
Mandates 60% of Renewable Portfolio Standard by 2030 and 100% by 2045

1. INTRODUCTION

DUCK CURVE



WHY NOT USE BEVs TO REDUCE THE RESIDENTIAL LOAD?

2. CONTRIBUTIONS


MODEL ACCOMPLISHMENT

Circuit capacity	10369 kW	Input parameter		Solver parameter	Function	Output
Threshold	0.02			Objective	10% peak load decrease	10%
Load increase	0%			Changing	Threshold	0.02
				Constraints	Discharge rule <1	0.47
					% battery withdrawn	16%

n of household	4260 household	Energy discharged per EV	13.7 kWh
n of cars	8798 cars	Battery size	88 kWh
V2G availability	4.5%	% battery withdrawn	16%
BEV V2G 2030	441 BEVs		
Power station discharge	17.2 MW		
Discharge efficiency	90%		
Max power discharge	8.5 kW		
Battery size	88 kWh		

				Max peak load decrease	10%
--	--	--	--	------------------------	-----

41	2022 Load	Assumed increase	Fixed increase	2030 Load	% cars home	BEV availables	Energy discharged	Discharge rule	2030 load / V2G	Peak Load decrease	Energy discharged per BEV per hour
1	6241 kWh	26%	26%	7842 kWh	99%	437 BEVs		0.00	7842 kWh		
2	6692 kWh	22%	22%	8030 kWh	99%	438 BEVs		0.00	8030 kWh		
3	6388 kWh	19%	19%	7592 kWh	100%	440 BEVs		0.00	7592 kWh		
4	5180 kWh	15%	15%	5866 kWh	100%	441 BEVs		0.00	5866 kWh		
5	5106 kWh	13%	13%	5788 kWh	99%	437 BEVs		0.00	5788 kWh		
6	5089 kWh	12%	12%	5703 kWh	96%	422 BEVs		0.00	5703 kWh		
7	5019 kWh	11%	11%	5689 kWh	87%	389 BEVs		0.00	5689 kWh		
8	5432 kWh	8%	8%	5862 kWh	68%	300 BEVs		0.00	5862 kWh		
9	5758 kWh	5%	5%	6034 kWh	51%	226 BEVs		0.00	6034 kWh		
10	6402 kWh	2%	2%	6519 kWh	42%	187 BEVs		0.00	6519 kWh		
11	7151 kWh	-3%	-3%	6917 kWh	38%	166 BEVs		0.00	6917 kWh		
12	7420 kWh	-7%	-7%	6910 kWh	36%	154 BEVs		0.00	6910 kWh		
13	7894 kWh	-7%	-7%	7177 kWh	33%	144 BEVs		0.00	7177 kWh		
14	7789 kWh	-6%	-6%	7400 kWh	28%	126 BEVs		0.00	7400 kWh		
15	8027 kWh	-1%	-1%	7971 kWh	28%	122 BEVs		0.00	7971 kWh		
16	8110 kWh	3%	3%	8312 kWh	33%	144 BEVs		0.00	8312 kWh		
17	8381 kWh	5%	5%	8827 kWh	46%	203 BEVs	318 kWh	0.24	8510 kWh	4%	1.0
18	8708 kWh	8%	8%	9432 kWh	68%	300 BEVs	921 kWh	0.47	8510 kWh	10%	3.1
19	8619 kWh	10%	10%	9456 kWh	82%	360 BEVs	946 kWh	0.41	8510 kWh	10%	2.0
20	8477 kWh	10%	10%	9313 kWh	88%	387 BEVs	803 kWh	0.32	8510 kWh	9%	2.1
21	8169 kWh	12%	12%	9187 kWh	91%	402 BEVs	677 kWh	0.28	8510 kWh	7%	1.7
22	7889 kWh	16%	16%	9267 kWh	94%	419 BEVs	747 kWh	0.23	8510 kWh	8%	1.8
23	7821 kWh	18%	18%	8887 kWh	96%	422 BEVs	367 kWh	0.13	8510 kWh	4%	0.8
24	6906 kWh	22%	22%	8420 kWh	96%	432 BEVs		0.00	8420 kWh		



Sensitivity analysis - MAX DISCHARGE RULE									
Change in peak load increase									
	0%	5%	10%	15%	20%	25%	30%	35%	40%
0.47	0%								
0.5%	4.24	4.40	4.67	4.74	4.90	5.07	5.24	5.40	5.57
1.5%	1.41	1.47	1.52	1.58	1.63	1.69	1.75	1.80	1.86
2.5%	0.85	0.88	0.91	0.95	0.98	1.01	1.05	1.08	1.11
3.5%	0.61	0.63	0.65	0.68	0.70	0.72	0.75	0.77	0.80
4.5%	0.47	0.49	0.51	0.53	0.54	0.56	0.58	0.60	0.62
5.5%	0.39	0.40	0.42	0.43	0.45	0.46	0.48	0.49	0.51
6.5%	0.33	0.34	0.35	0.36	0.38	0.39	0.40	0.42	0.43
7.5%	0.28	0.29	0.30	0.32	0.33	0.34	0.35	0.36	0.37
8.5%	0.25	0.26	0.27	0.28	0.29	0.30	0.31	0.32	0.33

Over 1

Sensitivity analysis - % Battery withdrawn									
Change in peak load increase									
	0%	5%	10%	15%	20%	25%	30%	35%	40%
16%	16%	17%	18%	19%	20%	21%	22%	24%	25%

Sensitivity analysis - MAX DISCHARGE RULE									
Change in power discharge									
	4 kW	5 kW	6 kW	7 kW	8 kW	9 kW	10 kW	11 kW	12 kW
0.47									
0.5%	7.63	6.10	5.09	4.30	3.81	3.39	3.05	2.77	2.54


Sensitivity analysis - % Battery withdrawn									
Change in peak load increase									
	0%	5%	10%	15%	20%	25%	30%	35%	40%
16%	0%	5%	10%	15%	20%	25%	30%	35%	40%
0.5%	140%	149%	159%	170%	181%	192%	203%	214%	225%

OUTPUTS

- Functional V2G model for the evaluation of the viability of V2G scenarios
- Algorithms and profound methodology to provide a thorough analysis

- % Battery withdrawn
- Discharge rule

3. METHODOLOGY




3. METHODOLOGY

INPUT DATA

Input data

1. Hourly load profile 2022
2. Circuit's customers distribution
3. Circuit's capacity
4. Threshold parameter
5. 2022-2030 hourly load increase
6. Load increase parameter
7. Car home status
8. Battery size pack 2030
9. Discharge efficiency
10. V2G availability



	Circuit 41	Circuit 445	Circuit 278	Circuit 1266	Circuit 320					
Residential customers	4260	87%	787	83%	3772	97%	1879	96%	3199	98%
Commercial customers	624	13%	165	17%	80	2%	81	4%	67	2%
Industrial customers	1	0%	1	0%	25	1%	5	0%	7	0%
Total customers	4885	100%	953	100%	3877	100%	1965	100%	3273	100%

	Circuit 41	Circuit 445	Circuit 278	Circuit 1266	Circuit 320
Forecast demand	8708 kW	2890 kWh	6217 kWh	5604 kWh	6095 kWh
Facility loading	84%	26%	50%	45%	49%
Circuit capacity	10369 kW	11115 kW	12434 kW	12454 kW	12439 kW


3. METHODOLOGY

INPUT DATA



Input data

- 1. Hourly load profile 2022
- 2. Circuit's customers distribution
- 3. Circuit's capacity
- 4. Threshold parameter
- 5. 2022-2030 hourly load increase
- 6. Load-increase parameter
- 7. Car home status
- 8. Battery size pack 2030
- 9. Discharge efficiency
- 10. V2G availability




Hour	2022-2030 increase %
1	25.66%
2	21.76%
3	17.88%
4	14.98%
5	12.97%
6	12.06%
7	10.72%
8	7.91%
9	4.81%
10	1.83%
11	-3.27%
12	-6.87%
13	-6.71%
14	-5.00%
15	-0.70%
16	2.50%
17	5.19%
18	8.31%
19	9.72%
20	9.87%
21	12.46%
22	15.89%
23	17.89%
24	21.92%

3. METHODOLOGY

INPUT DATA

Input data

1. Hourly load profile 2022
2. Circuit's customers distribution
3. Circuit's capacity
4. Threshold parameter
5. 2022-2030 hourly load increase
6. Load increase parameter
7. Car home status
8. Battery size pack 2030
9. Discharge efficiency
10. V2G availability



• Provided by the US Federal Highway Administration

• 2030 CEC EVs estimations
 • 2030 V2G chargers assumption

Number of households in circuit 41	Average number of cars per household in California	Number of cars in circuit 41 2030	Percentage of BEVs in California 2030	Number of Evs in circuit 41 2030
4260	2.3	9798 cars	14.9%	1460 BEVs

Number of BEVs in circuit 41 2030	V2G availability 2030	Number of BEVs with V2G capabilities 2030	% V2G 2030
1460 BEVs	30%	441 BEVs	4.5%

Sensitivity analysis - % Battery withdrawn (0% Load increase)								
Change in V2G %								
0.5%	1.5%	2.5%	3.5%	4.5%	5.5%	6.5%	7.5%	8.5%
140%	47%	28%	20%	16%	13%	11%	9%	8%

3. METHODOLOGY

EQUATIONS

$$\text{Fixed increase}_t = \text{Assumed increase}_t * (1 + \text{Load increase})$$

$$2030 \text{ Load}_t = 2022 \text{ Load}_t * (1 + \text{Fixed increase})$$

$$\text{BEV available}_t = \text{BEV V2G 2030} * \% \text{ cars home status}_t$$

$$2030 \text{ load V2G}_t = 2030 \text{ load}_t \quad \text{if } 2030 \text{ load}_t < \text{Circuit capacity} * \text{Threshold}$$

$$2030 \text{ load V2G}_t = \text{Circuit capacity} * \text{Threshold} \quad \text{if } 2030 \text{ load}_t > \text{Circuit capacity} * \text{Threshold}$$

$$\text{Energy discharged}_t = 2030 \text{ Load}_t - 2030 \text{ Load V2G}_t$$

$$\text{Peak load decrease}_t = \frac{2030 \text{ Load}_t - 2030 \text{ Load V2G}_t}{2030 \text{ Load}_t}$$

OUTPUTS

$$\text{Discharge rule}_t = \frac{\text{Energy discharged}_t}{\text{BEV available}_t * \text{Max power discharge}}$$


V2G charger load factor

Avg % discharged

$$\% \text{ battery withdrawn} = \frac{\sum_{t=1}^{24} \text{Energy discharged per BEV per hour}}{\text{Battery size}}$$



3. METHODOLOGY

Circuit 41	2022 Load	Assumed increase	Fixed increase	2030 Load	% cars home	BEV available	Energy discharged	Discharge rule	2030 load / V2G	Peak Load decrease	Energy discharged per BEV per hour
1	6241 kWh	26%	26%	7842 kWh	99%	437 BEVs		0.00	7842 kWh		
2	5692 kWh	22%	22%	6930 kWh	99%	438 BEVs		0.00	6930 kWh		
3	5388 kWh	18%	18%	6352 kWh	100%	440 BEVs		0.00	6352 kWh		
4	5180 kWh	15%	15%	5956 kWh	100%	441 BEVs		0.00	5956 kWh		
5	5106 kWh	13%	13%	5768 kWh	99%	437 BEVs		0.00	5768 kWh		
6	5089 kWh	12%	12%	5702 kWh	96%	422 BEVs		0.00	5703 kWh		
7	5319 kWh	11%	11%	5890 kWh	87%	383 BEVs		0.00	5889 kWh		
8	5432 kWh	8%	8%	5862 kWh	68%	300 BEVs		0.00	5862 kWh		
9	5758 kWh	5%	5%	6034 kWh	51%	225 BEVs		0.00	6034 kWh		
10	6402 kWh	2%	2%	6519 kWh	42%	187 BEVs		0.00	6519 kWh		
11	7151 kWh	-3%	-3%	6917 kWh	38%	166 BEVs		0.00	6917 kWh		
12	7420 kWh	-7%	-7%	6910 kWh	35%	154 BEVs		0.00	6910 kWh		
13	7694 kWh	-7%	-7%	7177 kWh	33%	144 BEVs		0.00	7177 kWh		
14	7789 kWh	-5%	-5%	7400 kWh	28%	125 BEVs		0.00	7400 kWh		
15	8027 kWh	-1%	-1%	7971 kWh	28%	122 BEVs		0.00	7971 kWh		
16	8110 kWh	3%	3%	8313 kWh	33%	144 BEVs		0.00	8312 kWh		
17	8391 kWh	5%	5%	8827 kWh	46%	203 BEVs	316 kWh	0.24	8510 kWh	4%	1.6 kWh
18	8708 kWh	8%	8%	9432 kWh	68%	302 BEVs	921 kWh	0.47	8510 kWh	10%	3.1 kWh
19	8619 kWh	10%	10%	9456 kWh	82%	360 BEVs	946 kWh	0.41	8510 kWh	10%	2.6 kWh
20	8477 kWh	10%	10%	9313 kWh	88%	387 BEVs	803 kWh	0.32	8510 kWh	9%	2.1 kWh
21	8169 kWh	12%	12%	9187 kWh	91%	402 BEVs	677 kWh	0.26	8510 kWh	7%	1.7 kWh
22	7988 kWh	16%	16%	9257 kWh	94%	412 BEVs	747 kWh	0.28	8510 kWh	8%	1.8 kWh
23	7521 kWh	18%	18%	8867 kWh	96%	422 BEVs	357 kWh	0.13	8510 kWh	4%	0.8 kWh
24	6906 kWh	22%	22%	8420 kWh	98%	432 BEVs		0.00	8420 kWh		



4. CASES OF STUDY & RESULTS


CASE 1: 10% PEAK LOAD DECREASE




Any peak load decrease value can be chosen.

	Circuit 41	Circuit 445	Circuit 278	Circuit 1266	Circuit 320
Residential consumers	4260	787	3772	1879	3199
Comercial consumers	624	165	80	81	67
Industrial consumers	1	1	25	5	7
% residential	87%	83%	97%	96%	98%
Facility loading	84%	25%	50%	45%	49%
Max load/consumer	2.0 kWh	3.7 kWh	1.6 kWh	3.0 kWh	1.9 kWh
Max peak load decrease	10%	10%	10%	10%	10%
Thershold required	0.82	0.27	0.49	0.44	0.51
Max discharge rule	0.47	0.66	0.31	0.60	0.35
Battery % discharged	16%	17%	9%	15%	9%

4. CASES OF STUDY & RESULTS



CASE 2: PEAK LOAD DECREASE MAXIMIZED



	Circuit 41	Circuit 445	Circuit 278	Circuit 1266	Circuit 320
Residential consumers	4260	787	3772	1879	3199
Comercial consumer	624	165	80	81	67
Industrial consumer	1	1	25	5	7
% residential	87%	83%	97%	96%	98%
Facility loading 2022	84%	25%	50%	45%	49%
Max load/consumer	2.0 kWh	3.7 kWh	1.6 kWh	3.0 kWh	1.9 kWh
Power discharge	7.2 kW	7.2 kW	7.2 kW	7.2 kW	7.2 kW
Max peak load decrease	15%	14%	22%	16%	21%
Thershold required	0.77	0.26	0.43	0.41	0.45
Max discharge rule	0.71	0.89	0.66	0.96	0.72
Battery % discharged	30%	30%	30%	30%	30%


Battery withdrawn < 30%
Discharge rule < 1

Determine the limits of the technology

4. CASES OF STUDY & RESULTS

CASE 1: 10% PEAK LOAD DECREASE

	Circuit 41	Circuit 445	Circuit 278	Circuit 1266	Circuit 320
Residential consumers	4260	787	3772	1879	3199
Comercial consumers	624	165	80	81	67
Industrial consumers	1	1	25	5	7
% residential	87%	83%	97%	96%	98%
Facility loading	84%	25%	50%	45%	49%
Max load/consumer	2.0 kWh	3.7 kWh	1.6 kWh	3.0 kWh	1.9 kWh
Max peak load decrease	10%	10%	10%	10%	10%
Thershold required	0.82	0.27	0.49	0.44	0.51
Max discharge rule	0.47	0.66	0.31	0.60	0.35
Battery % discharged	16%	17%	9%	15%	9%

- ↑ Residential distribution % ↓ 
- 👍 Circuits 278 & 320 👎 Circuits 41 & 445
- Circuits 41 & 445 similar residential % and battery depletion
- Highest discharge rule for Circuit 445

CASE 2: PEAK LOAD DECREASE MAXIMIZED

	Circuit 41	Circuit 445	Circuit 278	Circuit 1266	Circuit 320
Residential consumers	4260	787	3772	1879	3199
Comercial consumer	624	165	80	81	67
Industrial consumer	1	1	25	5	7
% residential	87%	83%	97%	96%	98%
Facility loading 2022	84%	25%	50%	45%	49%
Max load/consumer	2.0 kWh	3.7 kWh	1.6 kWh	3.0 kWh	1.9 kWh
Power discharge	7.2 kW	7.2 kW	7.2 kW	7.2 kW	7.2 kW
Max peak load decrease	15%	14%	22%	16%	21%
Thershold required	0.77	0.26	0.43	0.41	0.45
Max discharge rule	0.71	0.89	0.66	0.96	0.72
Battery % discharged	30%	30%	30%	30%	30%

- Peak load decrease values varying from 14-22%.
- % Battery withdrawn constrain reached
- Peak load decrease in 445 minimum: V2G challenge

4. CASES OF STUDY & RESULTS

CASE 1: 10% PEAK LOAD DECREASE

		Sensitivity analysis - Max discharge rule								
Initial		Change in power discharge								
0.47		4 kW	5 kW	6 kW	7 kW	8 kW	9 kW	10 kW	11 kW	12 kW
Change in V2G %	0.5%	7.63	6.10	5.09	4.36	3.81	3.39	3.05	2.77	2.54
	1.5%	2.54	2.03	1.70	1.45	1.27	1.13	1.02	0.92	0.85
	2.5%	1.53	1.22	1.02	0.87	0.76	0.68	0.61	0.55	0.51
	3.5%	1.09	0.87	0.73	0.62	0.54	0.48	0.44	0.40	0.36
	4.5%	0.85	0.68	0.57	0.47	0.42	0.38	0.34	0.31	0.28
	5.5%	0.69	0.55	0.46	0.40	0.35	0.31	0.28	0.25	0.23
	6.5%	0.59	0.47	0.39	0.34	0.29	0.26	0.23	0.21	0.20
	7.5%	0.51	0.41	0.34	0.29	0.25	0.23	0.20	0.18	0.17
	8.5%	0.45	0.36	0.30	0.26	0.22	0.20	0.18	0.16	0.15

		Sensitivity analysis - % Battery withdrawn									
Initial		Change in load increase									
16%		0%	5%	10%	15%	20%	25%	30%	35%	40%	
Change in V2G %	0.5%	140%	149%	159%	170%	181%	192%	203%	214%	225%	
	1.5%	47%	50%	53%	57%	60%	64%	68%	71%	75%	
	2.5%	28%	30%	32%	34%	36%	38%	41%	43%	45%	
	3.5%	20%	21%	23%	24%	26%	27%	29%	31%	32%	
	4.5%	16%	17%	18%	19%	20%	21%	23%	24%	25%	
	5.5%	13%	14%	14%	15%	16%	17%	18%	19%	20%	
	6.5%	11%	11%	12%	13%	14%	15%	16%	16%	17%	
	7.5%	9%	10%	11%	11%	12%	13%	14%	14%	15%	
	8.5%	8%	9%	9%	10%	11%	11%	12%	13%	13%	

Sensitivity analysis - % Battery withdrawn (0% Load increase)								
Change in V2G %								
0.5%	1.5%	2.5%	3.5%	4.5%	5.5%	6.5%	7.5%	8.5%
140%	47%	28%	20%	16%	13%	11%	9%	8%

CASE 2: PEAK LOAD DECREASE MAXIMIZED

		Sensitivity analysis - Max discharge rule								
Initial		Change in power discharge								
0.71		4 kW	5 kW	6 kW	7 kW	8 kW	9 kW	10 kW	11 kW	12 kW
Change in V2G %	0.5%	11.56	9.25	7.71	6.61	5.78	5.14	4.63	4.21	3.85
	1.5%	3.85	3.08	2.57	2.20	1.93	1.71	1.54	1.40	1.28
	2.5%	2.31	1.85	1.54	1.32	1.16	1.03	0.93	0.84	0.77
	3.5%	1.65	1.32	1.10	0.94	0.83	0.73	0.66	0.60	0.55
	4.5%	1.28	1.03	0.86	0.71	0.64	0.57	0.51	0.47	0.43
	5.5%	1.05	0.84	0.70	0.60	0.53	0.47	0.42	0.38	0.35
	6.5%	0.89	0.71	0.59	0.51	0.44	0.40	0.36	0.32	0.30
	7.5%	0.77	0.62	0.51	0.44	0.39	0.34	0.31	0.28	0.26
	8.5%	0.68	0.54	0.45	0.39	0.34	0.30	0.27	0.25	0.23

		Sensitivity analysis - % Battery withdrawn									
Initial		Change in load increase									
30%		0%	5%	10%	15%	20%	25%	30%	35%	40%	
Change in V2G %	0.5%	270%	282%	293%	306%	320%	333%	347%	360%	374%	
	1.5%	90%	94%	98%	102%	107%	111%	116%	120%	125%	
	2.5%	54%	56%	59%	61%	64%	67%	69%	72%	75%	
	3.5%	39%	40%	42%	44%	46%	48%	50%	51%	53%	
	4.5%	30%	31%	33%	34%	36%	37%	39%	40%	42%	
	5.5%	25%	26%	27%	28%	29%	30%	32%	33%	34%	
	6.5%	21%	22%	23%	24%	25%	26%	27%	28%	29%	
	7.5%	18%	19%	20%	20%	21%	22%	23%	24%	25%	
	8.5%	16%	17%	17%	18%	19%	20%	20%	21%	22%	

Sensitivity analysis - % Battery withdrawn (0% load increase)								
Change in V2G %								
0.5%	1.5%	2.5%	3.5%	4.5%	5.5%	6.5%	7.5%	8.5%
270%	90%	54%	39%	30%	25%	21%	18%	16%

5. CONCLUSION

- **Proved** that Bidirectional EVs can substitute grid upgrades
- Significant contribution to the **field of sustainable energy and transportation**
- Versatile **model** that empowers users to study and evaluate the viability of V2G scenarios
- Study how the characteristic of distribution lines affect the V2G simulation
- Analyze the **implications on EVs and V2G chargers** while discharging energy to the grid



IEEE ENERGY CONVERSION CONGRESS & EXPO PHOENIX, ARIZONA, USA ☀️ OCT. 20-24

VEHICLE-TO-GRID ANALYSIS TO REDUCE ELECTRICAL PEAK LOAD IN THE SAN DIEGO AREA IN 2030

Rafael Aranzabal¹, Jose Torre-Bueno², Sridhar Seshagiri³

¹ University of the Basque Country, Spain

² Center for Community Energy, San Diego, USA

³ San Diego State University, San Diego, USA

